



Product Service

# CERTIFICATE

No. Z1A 13 11 55162 041

**Holder of Certificate:** TESTBOY GmbHBeim Alten Flugplatz 3  
49377 Vechta  
GERMANY**Certification Mark:****Product:****Voltage tester  
two-pole****Tested  
according to:**EN 61243-3:2010  
ZEK 01.4-08

The product meets the safety and health requirements of the German Product Safety Act section 20 to 22 ProdSG. The certification marks shown above can be affixed on the product. It is not permitted to alter the certification marks in any way. In addition the certificate holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. See also notes overleaf.

**Test report no.:**

028-713030037-000

**Valid until:**

2018-11-17

**Date,** 2013-11-19

( Josef Wörl )

Page 1 of 2



Product Service

**CERTIFICATE****No. Z1A 13 11 55162 041****Model(s):** Testboy Profi III LED**Brand Name:** Testboy

**Parameters:**

rated voltage range:	6 - 1000 V~ 6 - 1400 DC
rated frequency range:	0 - 1000 Hz
rated temperature range:	-15°C - +55°C
degree of protection:	IP65
overvoltage category:	CAT IV 1000 V

**Factory(ies):** 79079